Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **November 8, 2013**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
GRAND CREEK RANCH	B13-0439	MONO SLAB	FAIL	*NO PERMIT/PLANS ON SITE*
SARACENO	B13-0455	FOUNDATION	PASS	
STATZ	B13-0356	ROOF COVER	PASS	
BERGMAN	B13-0092	GAS PIPING	PASS	
GALAVIZ	B13-0346	UNDERGROUND PLUMBING	PASS	
GRAND ARTS COUNCIL	B12-0472GL	BOARD WALK	FAIL	*NEEDS RAMPS AT EACH END*
BENEDETTINI	B13-0427GL	DRYWALL	PASS	
McGINNES	B13-0314	FRAME	FAIL	*NEEDS POST/BEAM CONNECTORS*
KNIGHT	B13-0163	STAIRS	PASS	
GILLIS	B13-0172	INSULATION	PASS	
CHAPIN	S12-0041	SEPTIC	PASS	*NEED LETTER FROM ENGINEER*
MILYKI RANCH LLC	B13-0162	ICE & WATER	PASS	
JOHNSON	B13-0440	FRAME/FINAL	PASS	
BEST	B13-0286	WOODSTOVE	PASS	
QUAD RANCH LLC	B13-0418	ICE & WATER	PASS	
PRICE	B13-0460GL	ICE & WATER	PASS	
VOLTZ	B13-0389	INSULATION	PASS	
KNIGHT	B09-0131	FINAL	PASS	
KNIGHT	B13-0102	FINAL	PASS	