

**Grand County Building Department
Daily Inspection Record**

DATE OF INSPECTION: **JULY 26, 2010**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS/FAIL	COMMENTS
THOMAS	B10-0066	PARTIAL INSULATION	PASS	
DAVIDSON	B10-0241HSS	FINAL	PASS	
VILLAGE HOMES	B07-0494G	DRYWALL	PASS	
WYNDHAM	B08-0347G	WALK THROUGH	OK	
WYNDHAM	B08-0437G		OK	
WILHELM	B10-0189GL	FOOTING	PASS	
ROCKY MTN REP	B10-0067	PIERS	PASS	
TAYLOR	B10-0191	FINAL	PASS	
INMAN	B10-0243GL	FRAME	PASS	
STAMM	B10-0190	FINAL	FAIL	ELECTRIC NOT COMPLETE NO TRUSS ENGINEERING NO SNOW STOPS THIS IS NOT A COMPLETE LIST
VAN DYKE	B09-0248	ROOF FINAL	PASS	
WENZEK	B10-0131	FINAL	FAIL	RAILINGS HAVE OPENINGS GREATER THAN 4" NO GRIPPABLE HAND RAILS
SIDWELL	B10-0251	REBAR	PASS	
HULSE	B10-0261	FINAL	FAIL	NOT READY
ERWIN	B10-0193	FINAL	PASS	