## Grand County Building Department Daily Inspection RESULTS

DATE OF INSPECTION: **November 20, 2013** 

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
NYCHKA	B13-0481	FINAL	PASS	
MALOUFF	B13-0403GL	ICE & WATER	PASS	
AYMOND	B13-0117	FRAME	FAIL	NEED POSITIVE CONNECTIONS ON DROPPED CEILING
GRAHAM	B13-0122	FINAL	FAIL	NEED SNOW STOPS
PRICE	B13-0460GL	FINAL	FAIL	NEED SNOW STOPS
LARSON	B13-0471K	FINAL	PASS	
INDEPENDENT GAS	S13-0023	FINAL	PASS	
HEYE	S13-0042	SEPTIC	PASS	
BOEVE	B13-0277GL	ICE & WATER	PASS	
BOEVE	B13-0277GL	FRAME	PASS	