Grand County Building Department
Daily Inspection Record

DATE OF INSPECTION: **MAY 24, 2010**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS/FAIL	COMMENTS
LITTLE HO	B09-0158	DRYWALL	Pass	
BURNETT	B08-0355	INSULATION	Pass	
THOMAS	B10-0066	FOOTING	FAIL	REBAR NEEDS TO MAINTAIN 3" CLEARANCE
BLUE VALLEY SPORTSMAN	B10-0092	SLAB	Pass	
BLUE VALLEY SPORTSMAN	B10-0093	SLAB	Pass	
SPROUSE	B09-0199	ICE AND WATER	CANCEL	BY CONTRACTOR
HENDERHAN	B10-0059K	ROOF FINAL	Pass	

PURGE INSPECTIONS

LAST NAME	PERMIT NUMBER	TYPE OF PROJECT	COMMENTS