Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **January 3, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
VANIMAN	B13-0268	DRYWALL	FAIL	*NEED FIRE RESISTIVE ASSEMBLY GARAGE CEILING*
PRATT	B13-0183	FRAME	FAIL	*NEED TRUSS ENGINEERING*