Grand County Building Department
Daily Inspection Record

DATE OF INSPECTION: **January 21, 2011**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
SORENSON	B08-0432	DRYWALL	PASS	
KEARNEY	B10-0389	FRAME	FAIL	NEEDS PLAN CHANGE
KEARNEY	B10-0389	MECHANICAL	FAIL	PROVIDE RETURN AIR FROM 2ND FLOOR
TRI STATE	B10-0470K	GAS	PASS	
TRI STATE	B10-0470K	DRYWALL	PASS	
WILHELM	B10-0189GL	PLUMBING	PASS	
ROCKY MTN REP	B10-0067GL	FRAME	PASS	
DUMAIS	B07-0665HSS	FINAL	FAIL	NOT COMPLETE
MILLER	B06-0690HSS	FRAME	FAIL	NOT READY
MADDUX	B08-0313HSS	FINAL	PASS	
HUGLEY	B08-0230HSS	FINAL	FAIL	NO HANDRAIL