Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **January 27, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
EHA/BURGO	B13-0509	INSULATION	PASS	
PRATT	B13-0183	INSULATION	PASS	
WILDWOOD LLC	B08-0440	FRAME	PASS	
BRANSTETTER	B13-0475HSS	FRAME	PASS	
DEVANEY	B13-0177	FRAME	FAIL	*Need access, venting & insulation in crawlspace*
WOODS/ARMSTRONG	B13-153	INSULATION	PASS	*Pending framing sign-off*