Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **APRIL 30, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
MARSTON/DUERR	B13-0321	INSULATION	PASS	
HERNANDEZ	B13-0443K	FRAME	FAIL	***NEED EGRESS WINDOW FROM BEDROOM***
HERNANDEZ	B13-0443K	INSULATION	FAIL	***NEED EGRESS WINDOW FROM BEDROOM***
MALLINSON	B14-0039	FOUNDATION	PASS	
ALEXANDER	B14-0049GL	DRYWALL	PASS	
BAUERLY	B14-0033	FINAL	PASS	
GRAND COUNTY BOCC	B14-0050HSS	FRAME	PASS	
GRAND COUNTY BOCC	B14-0050HSS	ROUGH PLUMBING	FAIL	***NEEDS VENT RAISED UP IN WALL***