Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **MAY 5, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
LAMAN	B14-0009	FOOTING	PASS	
AYMOND	B13-0117	PLUMBING	FAIL	*NOT FINISHED*
AYMOND	B13-0117	GAS PIPING	FAIL	*PROPANE DETECTOR SYSTEM NOT HOOKED UP*
CLAYTON	B13-0456	INSULATION	PASS	
CONGER	B14-0038	PARTIAL ICE & WATER	PASS	*CENTER SECTION ONLY*