Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **JUNE 17, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
MALLINSON	B14-0039	INSULATION	PASS	
CLAYTON	B13-0456	PIERS	PASS	
CLAYTON	B13-0456	HEAT & VENT	FAIL	*NEEDS FIRESTOP INSTALLED*
CLAYTON	B13-0456	ICE & WATER	PASS	
YMCA OF THE ROCKIES	B14-0098	DECK PIER	PASS	
BOSCHEN	B13-0454	ROUGH PLUMBING	PASS	
BOSCHEN	B13-0454	GAS	PASS	
BOSCHEN	B13-0454	FRAME	PASS	
BOSCHEN	B13-0454	ICE & WATER	PASS	
KENDRICK	B14-0150	FOOTING	PASS	
KENDRICK	B14-0150	ZONING	PASS	
ZINK	B14-0106GL	DRYWALL	PASS	*TO TUB AREAS REINSPECTION NEEDED*
BERGUM	B14-0086	ROOF COVER	PASS	
BERGUM	B14-0086	FINAL	PASS	
MARK STUENKEL FAMILY TRUST	B14-0144GL	FRAME SET BACK	FAIL	*BEAM DOES NOT BREAK ON BEARING POINT*