Grand County Building Department
Daily Inspection Record

DATE OF INSPECTION: **March 25, 2011**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
HANICK	B11-0008	FRAME	FAIL	NEED LETTER STATING THE ROOF MEETS 70LBS SNOW LOAD
BLAIR	B10-0463GL	FINAL	FAIL	NO TOWN SIGN OFF
BLAIR	B10-0463GL	ROOF	PASS	
SCOTT	B11-0025	PLUMBING	PASS	
SCOTT	B11-0025	FRAME	PASS	
LONG/ERLANDSON	B11-0004	FINAL	PASS	
HEALEY	B10-0408	ICE AND WATER	PASS	
SANDERS	B11-0047	HEAT AND VENT	PASS	
SANDERS	B11-0047	FINAL	PASS	