Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **JULY 9, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
FOSHA	B14-0203	ICE AND WATER	PASS	
OSTROM	B13-0264	DRYWALL	PASS	*NO FINAL INSPECTION WITHOUT ACESS HOLES TO ATTIC*
GOOD/AMATO	B14-0087	DRYWALL	PASS	
VILLALOBOS	B14-0160	ROOF COVERING	PASS	
VILLALOBOS	B14-0160	FINAL	PASS	
ORTELL	B06-0976	FINAL	FAIL	*NEED NAILS IN JOIST HANGERS*
YMCA OF THE ROCKIES	B14-0194	GAS	PASS	
SULLIVAN	B13-0395	ROOF COVERING	PASS	
SULLIVAN	B13-0395	FINAL	PASS	
LINKE-KREMPIN	S14-0007	SEPTIC	PASS	
COOPER	B11-0410	FINAL	PASS	