Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **JULY 10, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
RELLAFORD	B14-0107	FRAME	PASS	
GRAFF/SPENCER	B07-0405	FRAME	FAIL	*NEEDS JOIST HANGERS*
GRAFF/SPENCER	B07-0405	ROUGH PLUMBING	FAIL	*NEEDS CLEAN OUT*
GRAFF/SPENCER	B07-0405	GAS PIPING	PASS	
CLARKE	B12-0529	PIERS	PASS	
CLARKE	B12-0529	ICE AND WATER	PASS	
MCNERTNEY	B14-0136	ICE AND WATER	FAIL	*NOT DONE*
MCNERTNEY	B14-0136	FRAME	FAIL	*NEEDS ROUGH ELECTRICAL*
ZINK	B14-0106GL	FINAL	FAIL	*NEEDS TRASH REMOVED*
CHING	B14-0005	INSULATION	PASS	
ANDERSON	B13-0275	ICE AND WATER	PASS	
VEENSTRA	B12-0331	FOOTING	PASS	
VEENSTRA	B12-0331	ROUGH PLUMBING	PASS	
CLAYTON	B13-0456	FIREPLACE	PASS	
DEVIL'S THUMB RANCH	B13-0176	ROUGH PLUMBING	PASS	
DEVIL'S THUMB RANCH	B13-0176	GAS PIPING	FAIL	*NEED PRESSURE ON SYSTEM*
DEVIL'S THUMB RANCH	B13-0176	FRAME	FAIL	*NEED JOIST HANGERS*
WILLIAMS	S14-0012	SEPTIC	PASS	*NEEDS ALARM SYSTEM AND CONTROL FOR FINAL*
WILLIAMS	B14-0156	FOOTING	PASS	
CLARKE	D12-0004	DEMO	PASS	