Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **JULY 16, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
FARLAND	B14-0204	FOUNDATION	FAIL	*NEED SOIL ENGINEERING BEFORE FOOTING INSPECTION*
JOHNSON	B14-0223	HEAT AND VENT	PASS	
JOHNSON	B14-0223	GAS PIPING	PASS	
BARTOW	B13-0051	FINAL	PASS	
DART	B14-0161	ICE AND WATER	PASS	
DART	B14-0161	FRAMING	PASS	
PIERRE GLYNN REVOCABLE TRUST	B14-0158	UNDERGROUND PLUMBING	PASS	
TRUMBO/ TOBEY	B14-0212	FOOTING	PASS	
FLINK	B14-0226	GAS PIPING	PASS	
FLINK	B14-0226	FIREPLACE	PASS	
DEVIL'S THUMB RANCH	B13-0176	FRAMING	PASS	
GALAVIZ	B13-0346	DRYWALL	PASS	
LOLLAR, INC	B14-0216	FOOTING	PASS	*OKAY TO POUR BUT NEED LETTER FROM ENGINEER ON FOOTING WIDTH*
LOFTNESS	B14-0224	FOOTING	PASS	