Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **AUGUST 15, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
SCHILDGEN	B14-0029	ROUGH PLUMBING-UTILITY BLDG	PASS	
SCHILDGEN	B14-0029	FRAME-UTILITY BLDG	PASS	
SCHILDGEN	B14-0029	ICE & WATER-UTILITY BLDG	PASS	
MILLER STORAGE PROPERTIES, LLC	B14-0304	ICE & WATER-REROOF	PASS	
MESSERLI	B14-0232	FINAL-FURNACE	FAIL	*NO SHUT OFF FOR GAS; NO EXHAUST FAN*
POTTS	B14-0237	PIERS-2 PADS-GARAGE	PASS	
YMCA OF THE ROCKIES	B14-0258	FOOTING-YURT VILLAGE II	PASS	
JOHNSON	B14-0230	FOUNDATION-GARAGE	PASS	
GALAVIZ	B13-0346	ICE & WATER-SFD		*ONLY THE LEFT SIDE IS OKAY*
BROTHERS FAMILY TRUST	S14-0018	SEPTIC	PASS	
JOST	B14-0255	ICE & WATER-DECK	PASS	