Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **AUGUST 27, 2014**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
KREMMLING SANITATION DISTRICT	B14-0329	GAS PIPING-GAS SERVICE INSTALLED	PASS	
BOYD CHILDRENS TRUST	B14-0323	PIERS-PORCH	PASS	
RAYMOND	B14-0312GL	PIERS-DECK	PASS	*2ND HALF OKAY*
RAYMOND	B14-0312GL	FRAME-DECK	FAIL	*NEED LEDGER LOCKS OR LAGS; NO SCREWS HOLDING RIM TO HOUSE*
THAMANN	B14-0338	ICE & WATER-REROOF	PASS	
FLINK	B14-0226	FINAL-CONVERT WOOD TO GAS INSERT	PASS	
BARNHART	B14-0268	FOOTING-GARAGE	PASS	
MAS KES TRUST	B14-0314	FOUNDATION-SFD		
SORENSON	B14-0347	PIERS-DECK	PASS	
APPLEBY	B14-0056	DRYWALL-SFD	PASS	*OKAY TO TAPE, FIRE STOP IN FIREPLACE FAILS*
APPLEBY	B14-0056	ROOF COVERING-SFD	PASS	
YMCA OF THE ROCKIES	B14-0258	UNDER GROUND PLUMBING-YURT VILLAGE II	PASS	
SWEETMAN	S14-0024	SEPTIC		*RESCHEDULED*