

**Grand County Building Department
Daily Inspection RESULTS**

DATE OF INSPECTION: SEPTEMBER 22, 2014

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
TOWN OF GRAND LAKE	B14-0261GL	INSULATION-ALTERATION	PASS	
BUTTRAM FAMILY LTD PARTNERSHIP	B14-0306GL	FOUNDATION-SFD	FAIL	NEED EXPLANATION
KONEMAN	B14-0162	ROUGH PLUMBING-SFD	PASS	
KONEMAN	B14-0162	ICE & WATER-SFD	PASS	
KONEMAN	B14-0162	GAS PIPING-SFD	PASS	
FRIHAUF	B13-0399	FINAL-FINISH INTERIOR OF LOG SHELL	FAIL	NEED ADDRESS; NEED FIREPLACE FINISHED
CHING	B14-0005	FINAL-REPAIR DAMAGE FROM FROZEN PIPES	PASS	
JOSE & JUDITH RODRIGUEZ LIVING TRUST	B14-0123GL	FINAL-WINDOW REPLACEMENT	PASS	
JMA PROPERTY, LLC	B12-0567	INSULATION-GARAGE	PASS	
JMA PROPERTY, LLC	B12-0567	GAS PIPING-GARAGE	PASS	
HOWARD	B14-0054	FRAME-GARAGE	PASS	
HOWARD	B14-0054	ROOF COVERING-GARAGE	PASS	
VEENSTRA	B12-0331	CHIMNEY CHASE-SFD		COURTESY INSPECTION – NEED FIRE BLOCK FOR FRAME
ROBERT WHITFIELD TRUST	B14-0385	HEAT & VENT-FURNACE	FAIL	EXHAUST TOO CLOSE TO GROUND
OLSON	B14-0259	UNDERGROUND PLUMBING-SFD	PASS	
LOLLAR, LLC	B14-0216	ICE & WATER-ADDITION	PASS	
LOLLAR, LLC	B14-0216	GAS PIPING-ADDITION	PASS	
BECKSMITH	S14-0037	SEPTIC	PASS	NEED TO SEE HOOK UP FOR FINAL. OKAY TO COVER FIELD AND TANK PER ENGINEER.
PERITO	B14-0409HSS	GAS PIPING-XCEL PRESSURE TEST	PASS	
DANIELS	B14-0395	FRAME-DECK & ROOF EXTENSION	PASS	
LJH, LLC	B14-0207GL	FOOTING-SFD	FAIL	NOT READY