

**Grand County Building Department
Daily Inspection Record**

DATE OF INSPECTION: OCTOBER 18, 2011

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
RICKERSHAUSER	B11-0182GL	INSULATION	FAIL	
FINE	B11-0413	FRAME	FAIL	NO ACCESS FIREPLACES COMPLETED FIRST
FINE	B11-0413	INSULATION	FAIL	NO ACCESS
MELLOW	B11-0515	FINAL	PASS	
FOLLENWEIDER	B11-0440	UNDERGROUND PLUMBING	PASS	
FUCIK	B10-0164	FINAL	PASS	
THE TOWN OF TABERNASH LLC	B11-0520	PIERS	PASS	
HUNT	B11-0536	UNDERGROUND PLUMBING	PASS	
LAHRMAN	B11-0465	FOOTING	FAIL	REBAR NEEDS TO BE SUSPENDED (NOT TOUCHING GROUND)
WOOD	B10-0403	FRAME	FAIL	NEED GRIPPABLE HAND RAIL
WOOD	B10-0403	FINAL	FAIL	SEE ABOVE
KAZOKAS	B11-0496K	FOOTING	PASS	
CRANDELL	B11-0512	ROUGH PLUMBING	PASS	
WILCOX	B10-0435	PIER	PASS	
STENGEL	B11-0227	FINAL	PASS	
KENDRICK	B11-0463	FOUNDATION	PASS	
MAKOWSKI	B11-0219	FRAMING	PASS	
MAKOWSKI	B11-0219	ROOF COVERING	PASS	
JANSONS	B11-0455	FINAL	PASS	
HAMER	B11-0522	FINAL	PASS	