

**Grand County Building Department
Daily Inspection Record**

DATE OF INSPECTION: FEBRUARY 3, 2012

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
CROSS	B11-0497	FINAL	PASS	
ANTONOFF	B12-0011	DRYWALL	PASS	
HOYT		DRYWALL	FAIL	NEED 5/8 DRYWALL OR LETTER FROM ARCHITEC
C LAZY U RANCH	B11-0534	INSULATION	PASS	
C LAZY U RANCH	B11-0535	ICE AND WATER SHILD	PASS	