

**Grand County Building Department
Daily Inspection Record**

DATE OF INSPECTION: FEBRUARY 17, 2012

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
ODONNELL	B12-0015GL	ICE AND WATER	PASS	
HARDING AND CO	B11-0560	COURTESY FINAL	PASS	
SACHTLEBEN	B12-0003	FRAME	PASS	
SACHTLEBEN	B12-0003	ROUGH PLUMBING	PASS	
COORS	B12-0018	GAS	PASS	
COORS	B12-0018	FRAME	PASS	
COORS	B12-0018	HEAT AND VENT	PASS	
YOUNG	B11-0216	FINAL	FAIL	NEED CARBON MONOXIDE DETECTORS IN BEDROOMS OF OLD PORTION
EXPRESS HOMES	B12-0016K	HEAT AND VENT	PASS	
EXPRESS HOMES	B12-0016K	FINAL	PASS	
KENDRICK	B11-0463	ICE AND WATER	PASS	
KENDRICK	B11-0463	FRAME	PASS	
KENDRICK	B11-0463	ROUGH PLUMBING	PASS	
KENDRICK	B11-0463	GAS	PASS	
MUELLER	B11-0030GL	FINAL	PASS	
COOK	B10-0490HSS	FIRE WALL	PASS	
THE TOWN OF TABERNASH	B11-0520	FINAL	PASS	
OHOTTO	B12-0004K	GAS	PASS	