Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **JULY 24, 2013**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
BROWN	B13-0234	GAS	PASS	
LOTAN	B13-0161	ICE AND WATER	PASS	
McMINN	B12-0580	DRYWALL	PASS	
SOULE	B13-0220	FRAME	FAIL	*CANT SEE BLOCKING, NEED 2 MORE TIE DOWNS, PLAN CHANGE FOR THE DECK, PROVICE TRUSS ENGINEERING*
LILES	B12-0230	FRAME	PASS	
YOUNG	B13-0110	FRAME	PASS	
YOUNG	B13-0110	ROUGH PLUMBING	PASS	
DAY	B13-0014	FINAL	PASS	
MEADOW RIDGE	B13-0208	FRAME	PASS	
McCONATHY	B13-0140	FINAL	PASS	
SOLOMON	B13-0139	FRAME	PASS	
MEDICINE MOON HOLDINGS	B12-0375	PARTIAL FRAME	PASS	
MS MTN CONDO LLC	B13-0216	FRAME	PASS	