Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **JUNE 13, 2013**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
WILSON	B13-0151	GAS	PASS	
KEESEN	B13-0137	ICE AND WATER	PASS	
SECRIST	B13-0136	FOOTING	PASS	
CARLTON	B13-0147	PIER	PASS	
EXCELL KREMMLING, LLC	B13-0123	UNDERGROUND PLUMBING	PASS	
JOHNSON	B13-0094	FINAL	PASS	
BORGEN	B13-0093GL	PIER	PASS	
MANGUSO	B13-0114	FINAL	PASS	
STUART	B12-0414	FRAME	FAIL	***NEED ELECTRICAL ROUGH INSPECTION AND PLUMBING INSPECTION PRIOR TO FRAME***
HABITAT FOR HUMANITY	B12-0241HSS	FINAL	FAIL	***NO ADDRESS, FINISH LANDINGS, MUST INSULATE BASEMENT***
RIVER PINES AT SHADOW	B13-0036	FINAL	FAIL	***NOT READY***
MAHON	S13-0008	SEPTIC	PASS	***IST PHASE ONLY***