Grand County Building Department
Daily Inspection RESULTS

DATE OF INSPECTION: **SEPTEMBER 9, 2013**

LAST NAME OF OWNER	PERMIT NUMBER	TYPE OF INSPECTION	PASS FAIL	COMMENTS
DOKTER	B13-0339GL	ICE AND WATER	PASS	
ABATE	B13-0308	PIER	PASS	
LEITNER	B13-0307K	PIER	PASS	
VERNON	B13-0209	FINAL	FAIL	*NEED SNOW STOPS, HAND RAIL, POSITIVE CONNECTIONS*
WHEATLEY	B13-0205GL	FRAME	FAIL	*NO ACCESS FOR INSPECTION*
MILYKI RANCH LLC	B13-0162	SLAB	PASS	
SOMMERFELD	B13-0107	UNDERGOUND PLUMBING	FAIL	
SOMMERFELD	B13-0107	GAS	FAIL	*NO PIPE THROUGH WALL UNDER FINISH GRADE*
KILGALLEN	B12-0525	GAS	PASS	
WOODS/ARMSTRONG	B13-0153	UNDERGROUND PLUMBING	FAIL	*NO PLANS OR PERMIT AVAILABLE FOR INSPECTION*
WEINGARDT	B13-0302GL	FINAL	PASS	
MORE	B13-0338	FOOTING	PASS	